

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3175-1539:113 Page 1 of 1

CATEGORY: Air Filter Units

LISTEE: Filtration Group, Inc., 912 E. Washington St., Joliet, IL 60433
Contact: Joseph Benoit (815) 774-1289 Fax (815) 726-2765

DESIGN: Model "Fiberglass Throwaway" and "Synthetic Throwaway" dry type, throw-away rigid air filters. These filters are produced in various dimensions with a maximum thickness of 2". Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Class 2
Maximum Depth: 2"

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, size, direction of airflow and UL label.

APPROVAL: Listed as Class II throw-away air filter units.

11-26-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager